



Longshed Interior Renovations
Invitation to Bidders

Release Date: June 8, 2023

The following is a list of responses to questions submitted by prospective respondents to ECHDC ITB for Longshed Interior Renvoation.

Longshed Interior Renovation ITB – Q&A Matrix

Table with 3 columns: No., Question, Answer. Contains two rows of Q&A regarding MBE certification and bid bond requirements.



No.	Question	Answer
3	There is only one new electrical panelboard being added in this project. Are the short circuit studies specification section 260573.13 and coordination study specification section 26973.16 required for this project?	Specification sections 260573.13 and 26973.16 are not required for this project.
4	Do the Contract goals for MBE, WBE and SDVOB requirements as listed in specification section 00119 pages 13 and 16 apply to contracts that are under \$100,000?	No. Contract goals apply to contracts that exceed \$100,000.
5	What company currently maintains the existing fire alarm panel associated with this project?	Davis Ulmer